



HILLSBOROUGH TOWNSHIP BOARD OF FIRE COMMISSIONERS
BUREAU OF FIRE SAFETY

(908) 369-4313
(908) 369-0609 Fax
FireSafety@hillsboroughfiredistrict.com

379 SOUTH BRANCH ROAD
HILLSBOROUGH, NEW JERSEY 08844
Christopher C. Weniger, Chief Fire Marshal

INTEROFFICE MEMO

TO: Hillsborough Planning Board
Hillsborough Board of Adjustment

FROM: Christopher C. Weniger, Chief Fire Marshal

DATE: April 28, 2022

SUBJECT: Homestead Road, LLC
21-PB-25-MS/MSP



In regard to the above application, the Bureau of Fire Safety requires the following at this time:

- Fire hydrants required south east and south west corners of warehouse #1. Exact locations must be approved by Chief Fire Marshal. All fire hydrants must have a marker installed in accordance with Hillsborough Code 166-17. Fire Hydrant must have approved NST threads.
- Parking stalls in front of any fire hydrant or FDC must be yellow hatched "No Parking".
- Provide plan showing turn by turn movement for 47 foot long fire truck into out of and through out site, including approach and departure angles (specifications attached)
- Fire Department connections must be located off of building, locations to be approved by Chief Fire Marshal. FDCs must have a 5" Storz connection on a 30° down angle elbow with screen and cap. FDC sign required to be posted directly above and behind connection 6" min. letters, red in color on white background. Sign must be reflective. Building ID signs required at each FDC.
- Fire zones will be required along east and west driveways of warehouse 1 and along south driveway of warehouse 2; markings must comply with Hillsborough Township code chapter 169.
- All buildings must be equipped with a Knox Box and necessary keys, locations must be approved by Chief Fire Marshal
- Emergency access roads must be designed to hold the weight of fire apparatus. Both entrances must have bollards with a chain and Knox Padlock. Signs must be posted "NO PARKING-DO NOT BLOCK EMERGENCY ACCESS ROAD".
- Building addresses and directional signs must be approved by the Chief Fire Marshal and posted in accordance with Hillsborough Township code.



HILLSBOROUGH TOWNSHIP FIRE DISTRICT

908-369-4313

908-369-0609 (fax)

firesafety@hillsboroughfiredistrict.com

379 SOUTH BRANCH ROAD

HILLSBOROUGH, NJ 08844

HILLSBOROUGH LADDER 37

OVERALL LENGTH	568"
WHEEL BASE	271.5"
WIDTH	100"
HEIGHT	146"
GVW	69,300 POUNDS